

APPENDIX - VIII

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE**

NO. 2139/50

Date 15.07.23

It is certified that an inspection team headed by Satish Kumar, Environmental Officer (Name of Officers with designation) from Municipal Council Jehanabad (Name of Department/Office) inspected Pratibha Pallavan Public School, Babhna Kataiya, Pratibha Nagar, Aerodram, Jehanabad, Bihar- 804408 (Name & Address of the School) on 15.07.2023 and found that the Pratibha Pallavan Public School (Name of school) has safe sanitary facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the schoiol building & the campus .

The above valid for a period of One Year till above date.

Signature with Seal 7/15/23

Name कार्यपालक पब्लिक वर्यकारी

Designation नगरपसिद जहानाबाद

To

Pratibha Pallavan Public School
Babhna Kataiya Pratibha Nagar
Aerodram, Jehanabad 804408
(Name & Address of the Institution)

DESIGNATION 7/15/23

SAFE DRINKING WATER CERTIFICATE

Ref:- 1260

Date:- 28/06/23

It is certified that as per report water quality of drinking water of Pratibha Pallavan Public School, Add- Babhana Kataiya, Pratibha Nagar, Aerodrome Jehanabad has been found safe as per IS. 10500/2012

Water quality report attached.

Signature with seal:-

Ali Haider
28/06/2023

Executive Engineer
P.H. Division Jehanabad

Name :- Ali Haider

Designation:- Executive Engineer

Amir
28/06/2023
CHEMIST
P. H. E. D.,
JEHANABAD.

PUBLIC HEALTH ENGINEERING DEPARTMENT GOV. OF BIHAR

WATER QUALITY OF DRINKING WATER SOURCES

DISTRICT :- JEHANABAD
 NAME OF P.H. DIVISION :- JEHANABAD

SAMPLING DATE-22.06.2023

TESTING DATE-26.06.2023

SL. No.	PARTICULARS OF THE SAMPLE						PARAMETERS EXAMINED (Value in mg/L. except pH, otherwise mentioned)																
	District	Block	Gram-Panchayat	Village	Type of Source	Name of the Nearest Person/Institution	Turbidity	pH	Conductivity	Total Hardness	Total Alkalinity	Calcium	Magnesium	Chloride	Sulphate	Iron	Nitrate	Fluoride	T.D.S	Arsenic	Bacteria	Type of Contamination found	Remarks (safe or unsafe)
1	Jehanabad	Jehanabad	Nagar Parisad	Pratibha Nagar, Aerodrome	Ground Water	Pratibha Pallavan Public School	0.2	7.43	880	240	280	48.09	29.16	440	30.96	0.28	8.76	0.71	572	NT	-ve	NO	
Min-Max. Permissible Limit (I.S. 10500/1983)							1-05 NTU	6.5-8.5	-	200-600	200-600	75-200	30-100	250-1000	200-400	1.0	45	1.0-1.5	500-2000	0.01			

Remarks: Submitted Sample of Water Confirm to IS 10500-2012 with respect to above test.
 Signature of the Analyst.

Anmit
 28/06/2023

Signature of the CHEMIST
CHEMIST
 P. H. E. D.
 JEHANABAD.

P. H. E. D.
 26/06/2023

Executive Engineer
 P.H. Division Jehanabad
Executive Engineer
 P.H. Division Jehanabad

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.**

No. 816

Date: 27/06/2023

It is certified that an inspection team headed by Dr. Dev Das Chowdhury
and Dr. B.K. Jha, M.D. Sadar Hospital, Jehanabad (Name of Officers
with designation) from Sadar Hospital, Jehanabad (Name of
Department/Office) inspected the Pratibha Pallab Public School
Jehanabad (Name & Address of
the School) on 27.6.23 and found that the Pratibha Pallab Public
School, Jehanabad (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of One Year.

Remarks

School campus appeared
healthy and Hygienic.

Dr. Dev Das Chowdhury
27.6.23
Signature with Seal: Dr. Dev Das Chowdhury 27/6/23

Dr. B.K. JHA : Dr. Dev Das Chowdhury
Medical Officer : C.M.O. Jehanabad
A.S.J.P Sadar Hospital Jehanabad : Dr. Dev Das Chowdhury
Chief Medical Officer
Sadar Hospital, Jehanabad
Reg. No:-21534/84

To
The Principal
Pratibha Pallab Public School
Jehanabad

(Name & Address of the Institution)

